

Bound Gravel Test Certificates

t: 01772 440340 e: info@dcmsurfaces.com www.dcmsurfaces.com

Test subject	Test standard	Result
External fire exposure to roofs	EN 1187 test 4 - BROOF(t4) - Tested as a flat roof	The Bound Gravel did not ignite under CEN/TS:2012 Test 4 External fire exposure to roofs test.
Slip resistance	BS EN 7188; 1998	Minimum dry 82 Minimum wet 50
Elongation at break	BS2782 Part 3	100%
Tensile Strength	BS2782 Part 3	Min 10 N/mm2
Porosity	BS EN 12616:2013	
BBA Approval		